

NOTES:

1. CONTRACTOR SHALL BE RESPONSIBLE FOR PROTECTION OF EXISTING SEWER AND OTHER UTILITIES, PROPER BACKFILLING, COMPACTING, AND SURFACE RESTORATION.
2. CONTRACTOR MUST ACCURATELY SIZE AND PROCURE CONNECTION FITTINGS BASED ON THE EXISTING DISTRICT SEWER (MATERIAL AND DIAMETER) AND THE LATERAL SEWER (MATERIAL AND DIAMETER) TO BE CONNECTED.
3. CONTRACTOR SHALL MANUALLY BACKFILL AND COMPACT AROUND THE CONNECTION UNTIL A MINIMUM OF 12" OF COVER IS PLACED OVER THE PIPE AND CONNECTION.
4. WHEN ORDERING THE FATBOY INSERTA-TEE, PROVIDE THE EXISTING DISTRICT SEWER PIPE'S DIAMETER, WALL THICKNESS AND STIFFNESS AND THE LATERAL MATERIAL, DIAMETER, AND STIFFNESS (SDR) TO BE INSTALLED. WHERE CIPP LINERS ARE PRESENT, PROVIDE THE LINER THICKNESS FOR PROPER SIZING OF THE RUBBER SLEEVE.

